



SW: 28162100A				
RIF.	COM. N°	DESCRIZIONE	ESEGUITO	DATA
①	AD 7527	PRIMA ESECUZIONE	MC	19.03.15
		DENOMINAZIONE ELECT DIAGRAM PCDC 45_01T/1H with thermostats and humldstats		
A termini di legge e' vietato riprodurre o comunicare a terzi il contenuto del presente disegno. "Proprieta'" riservata.		CODICE E60001840	FOGLIO 1/2	NOTE PCDC board

## Key for electric diagram 45. 1T/1H for PCOC board

ID1	= External input: high temperature	CC	= Boiler interlock
ID2	= External input: low temperature	CF	= Chiller interlock
T/H 1	= Room temp./humidity sensor ZONE 1	RP	= Pump A relay
B5	= remote ON/OFF	RS	= Summer/Winter relay
B6	= Boiler alarm	R_AG/AUX	= Frost protection relay/ Periodic auxiliary function relay
B7	= Chiller alarm	T1	= Zone 1 electrothermic head
B8	= Summer/Winter selector	RD	= Interlock Realy Dehumidifier
T man	= Flow temperature sensor	Y/Y2	= 0-10V signal for the mixing valve proportional servomotor
Text	= Outdoor temperature sensor		

### NOTE:

- Output J3 - Boiler interlock - Contact rating 8 A - 250 Vac -  $\cos\phi = 1$
- Output J4 - PGD1 Large remote terminal connection via 6-wire telephone cable
- Output J10 - Chiller interlock - Contact rating 8 A - 250 Vac -  $\cos\phi = 1$
- Output J11 - Contact rating 5 A - 250 V AC -  $\cos\phi = 1$
- Output NO3 - Frost protection digital output, closed contact: frost protection function in progress. If the digital output is enabled from the advanced menu it is used for the periodic auxiliary function, closed contact: auxiliary function in progress. (The logic is invertible from the advanced menu)
- Output NO7 - Summer/Winter digital output, closed contact: Winter. (The logic is invertible from the advanced menu)
- Back-up relay always recommended. Also use change-over relays if you are using commons with different voltages
- Digital input ID1 - When the contact closes it requests high temperature from the thermostat
- Digital input ID2 - When the contact closes while the function is in progress, it requests low temperature from the thermostat (if enabled)
- Digital input B5 - Allows the system to be switched on or off remotely, when selected in the PCOC menu
- Digital input B6 - For connection of a boiler alarm circuit, where fitted by the boiler manufacturer
- Digital input B7 - For connection of a chiller alarm circuit, where fitted by the chiller manufacturer
- Digital input B8 - Allows the system to be switched in heating or cooling mode remotely, when selected in the PCOC menu
- The logic of the inputs can be inverted from the advanced menu
- For PCOC regulator input and output connections, use cables with a section that is proportional to the load (1,5 mm<sup>2</sup>)
- The current supply for the regulator and the supply for the 0-10V servomotor must be galvanically isolated, using either two transformers or one with two independent secondary circuits.
- If dehumidification is only carried out during the summer season every dehumidifier should be switched on from a corresponding electrothermic head equipped with a micro switch. When there is a request for dehumidification the electrothermic head is powered. When it opens the micro switch closes, in this way the dehumidifier switch on. (See the following diagram by way of example)




### WARNING!

For graphic the common terminals of the sensors are shown schematically connected at the most convenient points. When wiring, run all leads of the probes to the terminals of the adjustment device and make the common connections at that point. This measure prevents electromagnetic disturbances which compromise correct signal transmission. Avoid running the cables of the sensors and of the digital inputs together with the power cables. It is advisable to use shielded cables for the connection of the sensors.

### IMPORTANT!

T/H temperature and humidity sensors: before closing the T/H probes, check that jumpers DP1 - DP2 are positioned as in the figure.

This operation enables output "out H" of the probe with signal 4/20 mA for correct measurement of humidity.



**out H** = humidity output (0/1 Vdc o 4/20 mA)  
**M** = reference for both power supply and outputs  
**+ (G)** = power supply (12/24 V AC or 9/30 V DC)  
**ntc** = NTC resistive output  
**DP1** = OFF  
**DP2** = ON

<b>EMMET</b> S.P.A. <small>A termini di legge e' vietato riprodurre o comunicare a terzi il contenuto del presente disegno. Proprieta' riservata.</small>	DENOMINAZIONE ELECT DIAGRAM PCOC 45_01T/1H with thermostats and humilistats		
	CODICE E60001840	FOGLIO 2/2	NOTE PCOC board